

**CITY OF FORT SMITH SUPPLEMENTAL SPECIFICATION  
PORTLAND CEMENT CONCRETE PAVEMENT**

**SECTION 350** of the Standard Specifications for Public Works Construction, February 2008 Edition, is hereby amended as follows:

**350.02 MATERIALS**

Item A. CONCRETE shall be deleted and replaced with the following:

- A. CONCRETE. The concrete shall be Class "P" (4000 psi) as specified in Section 401 "Concrete General." Coarse aggregate shall have a gradation conforming to AASHTO M 43 (ASTM C 33) Size No. 467 or No. 57.

**350.03 SUBMITTALS**

The second sentence of Item A. CONCRETE MIX DESIGNS shall be deleted and replaced with the following:

Test data submitted shall include 28 day compressive strength test results.