


CONCRETE PIPE SUPPORT  
N.T.S.  
SS.3.1



**SELECTION CHART**

DIAMETER FORCE MAIN	AIR RELEASE VALVE
4" - 12"	2"
14" - 20"	3"
24" - 36"	4"

- NOTES:
1. SEE DETAIL WA.3.6 FOR DIMENSIONS AND DETAILS FOR THE CONCRETE VAULT.
  2. AIR RELEASE VALVE SHALL BE A.R.I. MODEL D-020 OR APPROVED EQUAL.

AIR RELEASE VALVE  
N.T.S.  
SS.3.2

Revision	Date	BY

Standard Drawings  
**SANITARY SEWER IMPROVEMENTS**  
Public Works Construction



**CITY OF FORT SMITH**  
Engineering Department  
623 Garrison Avenue, Room 409  
Fort Smith, Arkansas 72901  
Phone (479)784-2225 Fax (479)784-2245

Project:	Details
Date:	NOV 2012
Scale:	As Shown
Drawn By:	RBR
Dwg. No.:	SS3
Sheet No.:	14